

表 II-3 放流水水質調査結果

令和6年度

項目	調査地点	処理施設放流水											基準	
		令和6年						令和7年						
	調査月	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	
採水月日		4/23	5/14	6/4	7/9	8/6	9/10	10/8						
採水時刻		10:00	9:55	10:30	10:10	13:45	10:10	11:30						
気温	(°C)	27.7	27.3	28.2	32.7	35.1	29.1	29.0						
水温	(°C)	27.2	27.0	27.5	32.0	33.0	29.6	30.0						
地下水位		-	-	-	-	-	-	-	-	-	-	-	-	
透視度	(cm)	-	-	-	-	-	-	-	-	-	-	-	-	
水色・外観		-	-	-	-	-	-	-	-	-	-	-	-	
臭氣		-	-	-	-	-	-	-	-	-	-	-	-	
水素イオン濃度		7.9	7.6	7.8	7.6	7.6	7.4	7.9						5.8~8.6
生物学的酸素要求量(BOD)	(mg/l)	1.6	4.4	1.7	1.2	1.8	0.9	4.3						≤60
化学的酸素要求量(COD)	(mg/l)	5.8	6.1	3.9	5.6	6.4	5.3	4.8						≤90
浮遊物質量(SS)	(mg/l)	1未満	1.0	1未満	1未満	1未満	1未満	1未満						≤60
n-ヘキサン抽出物質量・鉱油類	(mg/l)	-	-	-	-	<1	-	-	-	-	-	-	-	≤5
n-ヘキサン抽出物質量・動植物油脂類	(mg/l)	-	-	-	-	<1	-	-	-	-	-	-	-	≤30
フェノール類	(mg/l)	-	-	-	-	<0.1	-	-	-	-	-	-	-	≤5
銅	(mg/l)	-	-	-	-	<0.01	-	-	-	-	-	-	-	≤3
亜鉛	(mg/l)	-	-	-	-	<0.01	-	-	-	-	-	-	-	≤5
溶解性鉄	(mg/l)	-	-	-	-	0.02	-	-	-	-	-	-	-	≤10
溶解性マンガン	(mg/l)	-	-	-	-	<0.01	-	-	-	-	-	-	-	≤10
クロム	(mg/l)	-	-	-	-	0.01	-	-	-	-	-	-	-	≤2
大腸菌群数	(mg/l)	-	-	-	-	0	-	-	-	-	-	-	-	≤3000
窒素	(mg/l)	15	17	20	25	12	7.2	11						≤120
全燐	(mg/l)	-	-	-	-	<0.1	-	-	-	-	-	-	-	≤16
ダイオキシン類	(pgTEQ/l)	-	-	-	-	0.000063	-	-	-	-	-	-	-	≤10
排水基準項目	カドミウム	(mg/l)	-	-	-	-	<0.003	-	-	-	-	-	-	≤0.1
	全シアン	(mg/l)	-	-	-	-	<0.1	-	-	-	-	-	-	≤1
	有機リン化合物	(mg/l)	-	-	-	-	<0.1	-	-	-	-	-	-	≤1
	鉛	(mg/l)	-	-	-	-	<0.01	-	-	-	-	-	-	≤0.1
	六価クロム	(mg/l)	-	-	-	-	<0.01	-	-	-	-	-	-	≤0.5
	ヒ素	(mg/l)	-	-	-	-	<0.005	-	-	-	-	-	-	≤0.1
	総水銀	(mg/l)	-	-	-	-	<0.0005	-	-	-	-	-	-	≤0.005
	アルキル水銀	(mg/l)	-	-	-	-	<0.0005	-	-	-	-	-	-	検出されないこと
	ポリ塩化ビフェニル	(mg/l)	-	-	-	-	<0.0005	-	-	-	-	-	-	≤0.003
	トリクロロエチレン	(mg/l)	-	-	-	-	<0.01	-	-	-	-	-	-	≤0.3
	トラクロロエチレン	(mg/l)	-	-	-	-	<0.01	-	-	-	-	-	-	≤0.1
	ジクロロメタン	(mg/l)	-	-	-	-	<0.02	-	-	-	-	-	-	≤0.2
	四塩化炭素	(mg/l)	-	-	-	-	<0.002	-	-	-	-	-	-	≤0.02
	1,2-ジクロロエタン	(mg/l)	-	-	-	-	<0.004	-	-	-	-	-	-	≤0.04
	1,1-ジクロロエチレン	(mg/l)	-	-	-	-	<0.02	-	-	-	-	-	-	≤0.2
	シス-1,2-ジクロロエチレン	(mg/l)	-	-	-	-	<0.04	-	-	-	-	-	-	≤0.4
	1,1,1-トリクロロエタン	(mg/l)	-	-	-	-	<0.3	-	-	-	-	-	-	≤3
	1,1,2-トリクロロエタン	(mg/l)	-	-	-	-	<0.006	-	-	-	-	-	-	≤0.06
	1,3-ジクロロプロパン	(mg/l)	-	-	-	-	<0.002	-	-	-	-	-	-	≤0.02
	チカラム	(mg/l)	-	-	-	-	<0.006	-	-	-	-	-	-	≤0.06
	シマジン	(mg/l)	-	-	-	-	<0.003	-	-	-	-	-	-	≤0.03
	チオベンカルブ	(mg/l)	-	-	-	-	<0.02	-	-	-	-	-	-	≤0.2
	ベンゼン	(mg/l)	-	-	-	-	<0.01	-	-	-	-	-	-	≤0.1
	セレン	(mg/l)	-	-	-	-	<0.005	-	-	-	-	-	-	≤0.1
	ふつ素	(mg/l)	-	-	-	-	<0.1	-	-	-	-	-	-	≤8
	ほう素	(mg/l)	-	-	-	-	0.77	-	-	-	-	-	-	≤10
	アンモニア,アンモニウム化合物等	(mg/l)	-	-	-	-	9.1	-	-	-	-	-	-	≤100
	1,4-ジオキサン	(mg/l)	-	-	-	-	<0.05	-	-	-	-	-	-	≤0.05